

Tank-Type Water Closet (Toilet) – MaP Test Report

Scope: Maximum Performance (MaP) Testing Protocol, Version 6.0

Testing Date: July 5, 2016	Report Date: August 23, 2016
Client Name: Duval Bathworks – by Cobban	Client Address: 2413 Weymouth Place, Vancouver, BC
Client Contact (Name and email): David Cobban, davidcobban@gmail.com	
Source of Sample: Manufacturer	Testing Completed at: IAPMO, Guangdong, China
Brand Name: Duval – by Cobban	Model Name:
Combination #: BT-0915-TDF	Bowl #: NA
	Tank #: NA
MaP Listing to be shown on MaP website as: Duval – by Cobban BT-0915-TDF	

PHYSICAL PROPERTIES		
Fixture Type: 1-pc	Flush Type: Dual-Flush	Flush Design: Gravity Flush
Bowl Type: Other	Bowl: Floor-mount	Bowl Outlet: Floor Outlet
Rough-in (if floor mount): 12-inch		Fill Valve Type: Pilot Valve
Flush Valve Type: Piston	Flapper Diameter: 3-in.	Trap Diameter (Ball Pass): 1-7/8-in.
Bowl Height: 15.5 inches	Ht. of Waterline: 5 – 7/8-in.	Ht. of Overflow Tube: 7-in.

FLUSH VOLUME	
Rated Full Flush: 4.5-L / 1.19-G	Measured Full Flush: 4.47-L / 1.18-G
Rated Reduced Flush: 3.3-L / 0.87 G	Measured Reduced Flush: 3.17 L / 0.84 G
Maximum Flush w/OEM flapper: 5.93 L / 1.57 G	Maximum Flush w/ Aftermarket flapper: NA

RESULTS	
WaterSense® Certified: No	If “Yes”, Certification Body Name and File #:
Type of MaP media used in test: Cased	MaP Flushing Performance Score: 1000g
Toilet Sample Tested/Approved by: IAPMO R&T Laboratory Project No.: 26415, Report No.: 2275-16028	

MaP Flushing Performance Score (grams): 1,000